



Department of Education
Region VI – Western Visayas
SCHOOLS DIVISION OF CAPIZ
Banica, Roxas City



SCHOOLS DIVISION ADVISORY No. 006, s. 2020
January 6, 2020

TO: Public Schools District Supervisors concerned
Public Elementary, Secondary & Integrated School Heads
School DRRM Coordinators
All others

**URGENT REPORT ON DAMAGES
RE: TYPHOON URSULA**

Please be advised that all schools are requested to comply with the online Report on Damages RE:Typhoon Ursula at <http://deped.in/UrsulaReport> and the attached Damages Assessment per Building. Deadline for the submission of the online report will be on January 9, 2020 or as soon as possible.

Compliance of all schools is a must.


SALVADOR O. OCHAVO, JR., EdD, CESO V
Schools Division Superintendent



DAMAGE ASSESSMENT PER BUILDING

NAME OF SCHOOL: _____
 REGION: _____
 DIVISION: _____
 MUNICIPALITY: _____
 SCHOOL ID: _____

DATE OF VISIT: _____
 INSPECTED BY: _____
 INSPECTED BY: _____

Attachments: Site Development Plan and Photographs

Building Number	#1	#2	#3	#4	#5	#6	#7	#8	#9	#10
Building Type										
Number of Storeys										
Total Number of Classrooms										
Classroom Dimension										
Classrooms still in use (Yes or No)										
Damaged by recent calamity (Yes or No)										
	Damage Ratio (%)	Damage Ratio (%)	Damage Ratio (%)	Damage Ratio (%)	Damage Ratio (%)	Damage Ratio (%)	Damage Ratio (%)	Damage Ratio (%)	Damage Ratio (%)	Damage Ratio (%)
COMPONENTS										
Roofing Sheets										
Ridge Roll										
Flashing										
Gutter										
Fascia Boards										
Purlins										
Trusses										
Ceiling Boards (Exterior)										
Ceiling Frame (Exterior)										
Ceiling Boards (Interior)										
Ceiling Frame (Interior)										
CHB Walls (Exterior)										
CHB Walls (Interior)										
Partition Wall (Boards)										
Partition Wall (Frame)										
Doors										
Windows (Front)										
Windows (Rear)										
Electrical Fixtures										
Electrical Wires										
Electrical Rough-ins										
Flooring										
Beams										
Columns										
AVERAGE DAMAGE RATIO	0	0	0	0	0	0	0	0	0	0

NUMBER OF CLASSROOMS (Affected by Recent Calamity)

TOTALLY DAMAGED										
PARTIALLY DAMAGED (Major)										
PARTIALLY DAMAGED (Minor)										
FOR FURTHER INVESTIGATION										
IN-GOOD CONDITION										

NUMBER OF CLASSROOMS (Not Affected by Recent Calamity)

TOTALLY DAMAGED										
PARTIALLY DAMAGED (Major)										
PARTIALLY DAMAGED (Minor)										
FOR FURTHER INVESTIGATION										
IN-GOOD CONDITION										

ASSESSMENT	CRITERIA 1	CRITERIA 2
Totally Damaged	80% - 100%	None
Partially Damaged (Major)	10% - 79%	1. Estimated cost of repair should not exceed the budget ceiling <i>(Change assessment to Totally Damaged if condition is not satisfied)</i>
Partially Damaged (Minor)	1% - 9%	1. Estimated cost of repair should not exceed P10,000 per classroom AND 2. No damage to columns, beams and exterior walls <i>(Change assessment to Partially Damaged (Major) if conditions 1 and 2 are not satisfied)</i>